Performance of the TPC with Micro Pixel Chamber readout: micro-TPC

Kentaro Miuchi

H. Kubo, T. Nagayoshi, A.Ochi, R. Orito,
A.Takada, T. Tanimori, M.Ueno
Kyoto University
2. μ-PIC Detector

3.

Micro-TPC, performance

-ray Imaging

Conclusions

IEEE-NSS2002 Norfolk,U.S.A 2002 Nov. 15



TPC for sub-mm fine tracking



OUR GOAL: micro-TPC as an "electric cloud chamber"

IEEE-NSS2002 Norfolk,U.S.A 2002 Nov. 15

Kentaro Miuchi

2. µ-PIC Detector

- Micro Pixel Chamber
 256anode + 256 cathode strips
 Fine position resolution
 High gain
- Discharge damage: small





PC readout

PIC Detector: the performance



µ -PIC Detector: X-ray imaging

test chart image (Xe:C₂H₆ 7:3)



spatial resolution

✓ knife edge test 400 µ m resulution

other images



Readout Electron

Preamplifier

- ATLAS amplifier shaper discriminator (ASD) chip (64ch/card

Position encoding module

- 5 FPGAs 40MHz clock





3. Micro-TPC, the Performance

■ Field cage 8cm drift length 0.4 kV/cm electric field +10 × 10cm² µ -PIC → micro-TPC





Drift velocity 4.7cm/ µ s
 No gain decrease for long drift length



-ray imaging with micro-TPC



Prototype

- ✓ microTPC
 - 10 × 10 × 8.0 cm³
- 🗸 Nal
 - 4" × 4" × 1" + 25 PMTs

IEEE-NSS2002 Norfolk,U.S.A 2002 Nov. 15

Idea

- / micro-TPC : electron energy & track
- scintillator: scattered energy & position

reconstruct the gamma-rays (NOT A EVENT CIRCLE)

Nal



57Co (122keV



-ray imaging with micro-TPC



5. Conclusions

µ -PIC improvements gain : >10⁴ stable operation with gain >5000 Readout electronics DAQ rate: 7.7 Mcps **D** Micro-TPC **3D electron tracks** Gamma-ray imaging gamma-rays: reconstructed

IEEE-NSS2002 Norfolk,U.S.A 2002 Nov. 15

Kentaro Miuchi